



CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/25/SH/00430

Contract Number: 801410

Certificate Project Number: SH-CERT250504332

Certified Product: DC Energy Storage System

Trademarks: PYTES

Model(s): V5°α Plus ESS

Technical Data: V5°α Plus ESS includes Batteries of V5°α Plus and Battery Boxes or Brackets. Battery Type LFP, Battery Voltage Range 47.5Vdc~57.6Vdc, Max Charge / Discharge Current 75A for each pack, Max Energy Output 5.12kWh for each pack, up to 12 battery packs in parallel, Charge Temperature 2~57°C, Discharge Temperature -18~57°C, 6000 cycles.; Other Ratings : IP20

Certificate Holder: Shanghai PYTES Energy Co., Ltd.
No.3492 Jinqian Road, Qingcun Town, Fengxian District, Shanghai, 201400, China

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:

ANSI/CAN/UL 9540:2023, Third Edition, Dated June 28, 2023

Authorized by:

Effective date: 26 September 2025



Mark Lohmann
Certifier



Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

