



Ref. Certif. No.

SG PSB-BT-07119

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Batteries (Rechargeable Li-ion Battery System)
Name and address of the applicant	Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road Fengxian District 201406 Shanghai PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road, Fengxian District, 201406 Shanghai, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road, Fengxian District, 201406 Shanghai, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	See page 2
Model/type Ref.	HV48100 SE BMU-3, HV48100 SE BMU-4, HV48100 SE BMU-5 HV48100 SE BMU-6, HV48100 SE BMU-7, HV48100 SE BMU-8 HV48100 SE BMU-9, HV48100 SE BMU-10, HV48100 SE BMU-11 HV48100 SE BMU-12, HV48100 SE BMU-13, HV48100 SE BMU-14 HV48100 SE BMU-15
A sample of the product was tested and found to be in conformity with	IEC 62619:2022
as shown in the Test Report Ref. No. which forms part of this certificate	085-282560506-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003364 0037 Rev. 00

Date, 2025-09-29

(Ryan Jin)

TÜV SÜD PSB Pte Ltd

15 International Business Park TÜV SÜD @ IBP

Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-BT-07119

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Trademark / Brand (Image)

Pytes

Ratings and principal characteristics

Nominal voltage: HV48100 SE BMU-3: 153.6 Vd.c.
HV48100 SE BMU-4: 204.8 Vd.c.
HV48100 SE BMU-5: 256 Vd.c.
HV48100 SE BMU-6: 307.2 Vd.c.
HV48100 SE BMU-7: 358.4 Vd.c.
HV48100 SE BMU-8: 409.6 Vd.c.
HV48100 SE BMU-9: 460.8 Vd.c.
HV48100 SE BMU-10: 512 Vd.c.
HV48100 SE BMU-11: 563.2 Vd.c.
HV48100 SE BMU-12: 614.4 Vd.c.
HV48100 SE BMU-13: 665.6 Vd.c.
HV48100 SE BMU-14: 716.8 Vd.c.
HV48100 SE BMU-15: 768 Vd.c.

Rated capacity: 100 Ah

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003364 0037 Rev. 00

Date, 2025-09-29

(Ryan Jin)



TÜV SÜD PSB Pte Ltd

15 International Business Park TÜV SÜD @ IBP

Singapore 609937

PSB Singapore